

- 2. BOTTOM BENCH SHALL BE CONSTRUCTED FIRST AND SOLID DRAIN PIPES PLACED BEFORE UPPER BENCHES CONSTRUCTED.
- 3. CONTRACTOR SHALL LIMIT BENCH HEIGHT AND LIMITS OF CONSTRUCTION SUCH THAT SLOPE FAILURES OR SLOUGHING OF THE EXISTING EMBANKMENT DO NOT OCCUR.
- 4. SOLID DRAIN PIPES SHALL BE PLACED AT MINIMUM 200-FOOT INTERVALS.

GEOGRID REINFORCED SLOPE EMBANKMENT INTERNAL DRAINAGE DETAILS

NO SCALE